

## Retail Fireworks Stand Inspection

### GENERAL

- TCESD # 3 Permit for each retail stand not connected.
- All Operators must be at least 16YOA on duty.  
34.817(g)
- No Smoking inside or within 10' of stand.  
34.817(g)
- No Operator can consume or be under the influence of alcohol.  
34.817(g)
- No Fireworks can be sold or offered to children under 12 YOA.  
Sec. 17(d)
- Cannot Sell <100' from storage & dispensing of flammables.  
Sec 17(f2)
- Adequate off road parking provided.  
34.817(1)
- NO SMOKING signs at least 4" letters, posted.  
34.917(g)
- No Trash or cardboard boxes within 10' of stand.  
38.817(m)
- No High grass/weeds within 10' of stand.  
34.817(m)
- A Suitable lock to prevent unauthorized entry when closed.  
38.818(d)
- A minimum distance of six feet shall be maintained from the front of the customer counter to the back side of the stand.
- A minimum of combustible material such as posters, signs, and decorations may be used on interior walls.
- The fireworks stand in which Fireworks 1.4G are held for retail sale shall be constructed of wood, metal, masonry, concrete or combinations thereof.

### EXITS

- Each stand of less than 16 feet in length shall have at least one walk door, which opens outward. Stands measuring 16 feet or longer must have at least two walk doors, one in each end, which open outward.
- Egress clear.  
34.817(e)
- Correct number of egress doors (>16' two doors).  
34.818(a)
- Egress doors open outward and unlocked when stand opened.  
34.817(d)

Inspection Date: \_\_\_\_\_ by: \_\_\_\_\_

## ELECTRICAL

- Electrical service is installed in accordance to NEC & AHJ.  
34.818(b3)
- Electrical service to the stand shall be installed at least eight feet above ground or buried underground.
- Each stand utilizing electricity shall have a point of power interruption, either inside or outside the stand, (switch or switches) located near an exit door which interrupts all electric supply to devices and equipment located inside and on the stand.
- All electrical wiring, equipment, and devices both inside and outside the stand, shall be UL approved, be securely mounted to the structure, and be installed and maintained to prevent electrical hazards. Splices in electrical wiring servicing equipment and devices inside the stand shall be enclosed in junction boxes. Light fixtures and wiring used for illumination inside and outside of the stand shall be installed and maintained to prevent accidental contact by the general public and employees.
- Drop cords with lights, extension cords, or bare wiring shall not be used in any manner inside a retail stand.
- Generator at least 10' from stand.  
34.818(b5)
- NO High grass, weeds, trash near generator.  
34.818(b5)
- 6 BC extinguisher on site for generator.  
34.818(b5)

## STRUCTURE

- No Selling from single/multifamily structure.  
34.817(k)
- No Selling fireworks from tent or motor vehicle.  
34.817(f)

## FIREWORKS

- Cannot sell illegal fireworks e.g. bottle rockets, M-80's. Sec 2(b)
- No Fireworks that do not conform to USCPS Labeling.  
34.817(o)
- No fireworks being discharged <100' from fireworks stand
- No displayed fireworks within reach of customer

Inspection Date: \_\_\_\_\_ by: \_\_\_\_\_